SONO LOOP 260 IP54 surface DIRECT

871-8126517O

PROJECT	
TYPE	
NOTES	
QUANTITY	
DATE	

GENERAL

Ceiling / Wall
Surface
white
IP54
IK07
881 lm
RAL9010 [a]

LED

3000 K
CRI ≥ 80
L90 / 50000 h
photobio. safety RG 0 - no Risk
initial MacAdam ≤ 3 SDCM
MR 0.54
MDER 0.49

OPTICAL

Opal

PHYSICAL

diameter 260 mm
height 82 mm
1.7 kg

ELECTRICAL

non DIM
7.6 W
116 lm/W
PC1 220-240V

[a] RAL Palette colors may deviate slightly due to production conditions.

IP54 IK 07 220-240V X-PERT

Round luminaire housing in die-cast aluminium; attached ring in rolled and seamlessly welded aluminium profile; surface white powder coated; suitable for wall or ceiling mounting; time saving installation through snap-in mounting system; LED board highly reflective lacquered for higher efficiency; same luminance for all size versions; light colour 3000 K; binning initial MacAdam ≤ 3 SDCM; CRI ≥ 80; min. 90% of luminous flux after 50000 operating hours; energy efficient LEDs with high CRI; completely homogeneously illuminated, satin PMMA cover; luminaire with 2 cable openings and plug-in terminal for through wiring; degree of protection IP54 (wall mounted) / IP50 (ceiling mounted); PC1 220-240V; photobiological safety according to IEC 62471 risk group RG 0 - no Risk; shock resistance IK07; internal wiring in light halogen free; incl. converter, non dimmable; light source not replaceable; control gear replaceable by an authorized professional;

Light Distribution

© XAL GmbH · Auer-Welsbach-Gasse 36 · 8055 Graz · Austria · www.xal.com

SONO LOOP 260 IP54 surface DIRECT

871-8126517O

Circuit Breaker Types

Automatic Circuit Breaker Type	Number of Fixtures
B10	30
B13	30
B16	37
B20	47
C10	38
C13	50
C16	61
C20	75

Maintenance Factors

Operating Time [h]	10 000	20 000	30 000	40 000	50 000
LLMF	0.98	0.95	0.93	0.91	0.9
LSF	1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF[a]	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF[a]	Luminaire Maintenance Factor	LSF	Lamp Survival Faktor

[a] According to “CIE 97, Maintenance of indoor electric lighting systems”, 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.

© XAL GmbH · Auer-Welsbach-Gasse 36 · 8055 Graz · Austria · www.xal.com